
IEC61508 Overall Safety Requirements and their Allocation Document for PSS0

| | Name | Role/Title |
|--------------------------|----------------|--|
| Owner | Fan Ye | PSS Safety Engineer, Isograph Expert, Engineering Safety Consultants Limited, UK |
| | Denis Paulic | Deputy Group Leader for Protection Systems Group, ICS |
| Reviewer | Stuart Birch | Senior Engineer - Personnel Safety Systems, ICS |
| | Michael Plagge | Occupational Health & Safety Engineer, ESH |
| Approver | Annika Nordt | Group Leader for Protection and Safety Systems Group, ICS |
| Distribution list | Timo Korhonen | Chief Engineer, Integrated Control System Division |
| | Ralf Trant | Associate Director, ESH&Q |
| | Yong Kian Sin | Electrical Controls Engineer- Personnel Safety Systems, ICS |

| TABLE OF CONTENT | | PAGE |
|-------------------------|---|-------------|
| 1. | SCOPE..... | 5 |
| 2. | CONTRIBUTORS..... | 5 |
| 3. | ISSUING ORGANISATION | 5 |
| 4. | INTRODUCTION | 5 |
| 4.1. | Objectives..... | 5 |
| 4.2. | Scope..... | 5 |
| 4.3. | List of SIFs..... | 6 |
| 4.4. | SIL Determination..... | 7 |
| 4.4.1. | General..... | 7 |
| 4.4.2. | Information Used in the LOPA | 7 |
| 4.5. | SIL Verification..... | 8 |
| 5. | ASSUMPTIONS..... | 8 |
| 5.1. | Introduction | 8 |
| 5.2. | SIL Determination Assumptions..... | 8 |
| 5.3. | SIL Verification Assumptions | 10 |
| 6. | METHODOLOGY | 11 |
| 6.1. | Methodology for SIL Determination | 11 |
| 6.1.1. | General Concept of Risk Reduction | 11 |
| 6.1.2. | Risk and Safety Integrity Level | 12 |
| 6.1.3. | Risk Targets | 13 |
| 6.1.4. | SIL Determination using LOPA | 13 |
| 6.1.4.1. | General..... | 13 |
| 6.1.4.2. | The LOPA Process for Low Demand SIFs | 14 |
| 6.1.4.3. | The LOPA Process for High or Continuous Demand SIFs | 15 |
| 6.1.4.4. | Independent Protection Layers (IPLs) | 15 |
| 6.1.5. | SIL Determination Results..... | 16 |
| 6.2. | Hardware Reliability Assessment Methodology | 16 |
| 6.2.1. | Definition of Safety Integrity Level | 16 |
| 6.2.2. | Probability of Failure on Demand | 17 |
| 6.2.3. | Failure Rate, λ | 17 |
| 6.2.3.1. | General..... | 17 |

| | | |
|----------|---|----|
| 6.2.3.2. | Failure Modes..... | 17 |
| 6.2.3.3. | Diagnostic Testing | 18 |
| 6.2.4. | PFD and Mean Down Time (MDT) | 18 |
| 6.2.4.1. | General..... | 18 |
| 6.2.4.2. | PFD for Detected Failures | 19 |
| 6.2.4.3. | PFD for Undetected Failures..... | 19 |
| 6.2.4.4. | PFD for Subsystem..... | 19 |
| 6.2.4.5. | PFH for Subsystem..... | 19 |
| 6.2.5. | Voting Configurations..... | 20 |
| 6.2.6. | Common Cause Failure (CCF)..... | 20 |
| 6.3. | Architectural Assessment Methodology | 20 |
| 6.3.1. | Hardware Fault Tolerance (HFT) | 20 |
| 6.3.2. | Safe Failure Fraction (SFF) | 21 |
| 6.3.3. | IEC 61508 Architectural Constraints (Route 1 _H) | 21 |
| 7. | RESULTS..... | 22 |
| 8. | CONCLUSIONS AND RECOMMENDATIONS | 24 |
| 9. | GLOSSARY..... | 24 |
| 10. | REFERENCES | 25 |
| 11. | APPENDIX A – SIF DEFINITIONS | 27 |
| 12. | APPENDIX B – IPL REGISTER..... | 30 |
| 13. | APPENDIX C – SIL ASSESSMENT WORKSHEETS..... | 32 |
| 14. | APPENDIX D – FAILURE RATE DATA | 41 |
| 15. | APPENDIX E – ETA..... | 44 |
| | DOCUMENT REVISION HISTORY | 48 |

LIST OF TABLES

| | | |
|----------|---|----|
| Table 1. | List of SIFs..... | 6 |
| Table 2. | IPL Guidance | 9 |
| Table 3. | SIL Specified PFD | 12 |
| Table 4. | HFT for Type A and Type B Components | 21 |
| Table 5. | Summary of Results – LOW Demand SIFs..... | 22 |
| Table 6. | Summary of Results – HIGH Demand SIFs | 23 |

LIST OF FIGURES

Figure 1: IEC 61511 Functional Safety Assessment Lifecycle Diagram..... 6
Figure 2. The Concept of Risk Reduction..... 12

Review

1. SCOPE

This report is the IEC61508 Overall Safety Requirements and their Allocation Document for European Spallation Source (ESS) ERIC Personnel Safety System 0 (PSS0). The report provides a Safety Integrity Level (SIL) assessment of the PSS0 Safety Instrumented Functions (SIFs).

The scope of the SIL assessment is limited to the five safety functions identified within the PSS0 Hazard and Risk analysis document ESS-0229506 [1].

2. CONTRIBUTORS

- Dr Fan Ye
- Denis Paulic
- Stuart Birch
- Morteza Mansouri

3. ISSUING ORGANISATION

- Integrated Control System (ICS) Division, European Spallation Source ERIC.

4. INTRODUCTION

4.1. Objectives

This report documents a SIL assessment of the PSS0, conducted in accordance with IEC 61508 [2] and IEC 61511 [3]. The objective of the study was to identify required levels of risk reduction, expressed in terms of SILs, and to verify that the corresponding SIFs meet these targets.

This report documents the:

- Determination of the potential frequency and consequence of agreed hazards;
- Determination of the risk reduction provided by other measures and the resulting risk gap, if any;
- Assignment of SIL requirements for SIFs to any resulting risk gaps in accordance with IEC 61508 [2] and IEC 61511 [3];
- Verification of SIFs against SIL requirements in terms of random hardware reliability and minimum architecture;
- Recommendations for addressing any shortfalls.

4.2. Scope

The scope of this study was limited to the PSS0 Hazards and SIFs identified in the PSS0 Hazard and Risk Analysis document ESS-0229506 [1], supported by the PSS0 Hazard Register [4].

The study assesses the potential risks to the safety of personnel.

This document covers Safety Lifecycle Phases 4 and 5 from IEC 61508 [2]: Overall Safety requirements and Overall Safety requirements allocation.

The document addresses the requirements of IEC 61511 [3] Phase 2 and Phase 4, as described in the Functional Safety Assessment (FSA) Lifecycle diagram, for hazards that can be directly addressed by the implementation of a SIF.




Figure 1: IEC 61511 Functional Safety Assessment Lifecycle Diagram.

4.3. List of SIFs

Table 1 gives a summary of the SIFs and the corresponding Hazard IDs. A more detailed definition of the SIFs can be found at Appendix A (Section 11).

Table 1. List of SIFs

| Hazard ID | SIF Tag | SIF Description | Mode of Operation |
|----------------|---|---|-------------------|
| N/A | SIF01 – HV emergency stop | Upon detecting the emergency stop button being pressed, shutdown HV by removing its power supply (1oo2 relay and contactor) via Safety PLC (1oo2, blue and red trains). | Low Demand |
| HAZ003 IE01 | SIF02 – HV interlock upon intrusion to PSS0 Controlled Area | Upon detecting access gate in open position (1oo2 position switch), shutdown HV by removing its power supply (1oo2 relay and contactor) via Safety PLC (1oo2, blue and red trains). | Low Demand |

| Hazard ID | SIF Tag | SIF Description | Mode of Operation |
|-------------|--|---|-------------------|
| HAZ003 IE02 | SIF03 – HV interlock – PSSO Key Exchange | Upon detecting access key is removed (key switch in off position), shutdown HV by removing its power supply (1002 relay and contactor) via Safety PLC (1002, blue and red trains). Additionally, it also closes an earth relay to remove any residual stored energy from the power supply and its output cable. | High Demand |
| HAZ003 IE01 | SIF04 – Door lock – PSSO Key Exchange | Upon detecting access key is removed from Slot 2, lock the Access Gate (de-energising 1001 solenoid) via Safety PLC (1002, blue and red trains). | High Demand |
| HAZ003 IE01 | SIF05 – HV On warning light | HV ON warning light activated when Access Key at Slot 1 in On position. | High Demand |

Notes:

- SIF01 was designed to prevent equipment damage in cases of fire or explosion. It is not used for personnel protection and not taken as safeguard for the electric shock hazard. Therefore it has been excluded from any further assessment.
- SIF05 is not a SIF by definition, as it does not put the system in a safe state. However, this function is provided by PSSO. It will be treated as part of administrative control and excluded from any further assessment.

4.4. SIL Determination

4.4.1. General

The assignment of SIL targets was achieved using the Layers of Protection Analysis (LOPA) technique. The LOPA methodology is presented in Section 6.1, and follows the process described in IEC 61511-3 [3] and the American Institute of Chemical Engineers (AIChE) CCPS LOPA 2001 [5]. The LOPA was conducted using ESC’s in-house software package: ProSET® v.5.6.1.0.

The LOPA worksheets are presented in Appendix C (Section 13).

4.4.2. Information Used in the LOPA

The following information was provided by ESS PSS team for use in the LOPA study:

- PSSO Hazard and Risk Analysis document ESS-0229506 [1]
- PSSO Hazard Register ESS-0229491 [4]

4.5. **SIL Verification**

The random hardware reliability assessment was performed using isograph FaultTree+ software package, which utilises the Fault Tree Analysis (FTA) method. The hardware reliability assessment methodology is presented in Section 6.2.

An architectural constraints assessment was performed by following Route 1_H of IEC 61508 [2] and the methodology is presented in Section 6.3.

5. **ASSUMPTIONS**

5.1. **Introduction**

The following sections detail the data and assumptions applied in the analysis and provide justification for each item.

5.2. **SIL Determination Assumptions**

This section presents the assumptions and rule set applied in this analysis.

In accordance with the risk matrix presented in the PSS0 Hazard Register [4], the risk target of 1.0E-06 per year has been selected for the LOPA study for analysing the electric shock hazard.

Initiating events frequencies from the PSS0 Hazard and Risk Analysis document [1] were used in the study, as agreed with the ESS PSS team.

Table 2 lists the typical IPLs and associated acceptance criteria applied in the study as guidance, as agreed with ESS PSS team. Justification for these typical data is provided in the ESC Standard LOPA Rule Set [7].

Table 2. IPL Guidance

| Device | Typical PFD | Minimum Acceptance Criteria |
|--|-------------|---|
| Alarm (with preventative action in the Control Room) | ≥ 0.1 | <p>The time between annunciation of the alarm and the hazardous event occurring is ≥ 10 minutes;</p> <p>Operator is trained on alarm response;</p> <p>Operator practices the action periodically;</p> <p>Change on alarm setting is governed by strict Management of Change procedure;</p> <p>Control Room operator error was not the initiating event;</p> <p>The operator has an adequate alarm system;</p> <p>There are written procedures stating the operator action;</p> <p>Alarm falls within safe upper and lower limited and allows timely response from the control room.</p> |
| Alarm (with preventative action in the field) | ≥ 0.1 | <p>The time between annunciation of the alarm and the hazardous event occurring is ≥ 30 minutes;</p> <p>Operator is trained on alarm response;</p> <p>Operator practices the action periodically;</p> <p>Change on alarm setting is governed by strict Management of Change procedure;</p> <p>Control Room operator error was not the initiating event;</p> <p>The operator has an adequate alarm system;</p> <p>There are written procedures stating the operator action;</p> <p>Alarm falls within safe upper and lower limited and allows timely response from control room.</p> |

| Device | Typical PFD | Minimum Acceptance Criteria |
|----------------------|-------------------------------|---|
| BPCS Protective Loop | ≥ 0.1 | <p>The control loop runs in automatic mode and is subject to access and security control;</p> <p>The loop in question is independent of the initiating or enabling events;</p> <p>The loop is independent of any other device, system or action that is already being credited as an IPL for the same scenario;</p> <p>The control loop (Sensor, Logic and Control valve / contactor) is independent from the SIF for which the SIL target is being set.</p> |
| SIL1 SIF | $\geq 10^{-2}$ to $< 10^{-1}$ | IPL credit can be taken for a SIF if all the following conditions are met: |
| SIL2 SIF | $\geq 10^{-3}$ to $< 10^{-2}$ | <p>The sensor and final element subsystems are completely independent from the SIF under consideration;</p> <p>The SIF (comprising sensor, logic and final element subsystems) is independent of the initiating event;</p> |
| SIL3 SIF | $\geq 10^{-4}$ to $< 10^{-3}$ | <p>The SIF must be assigned a SIL target in relation to the credit given for risk reduction and thus must meet ALL requirements (including PFD verification) of the respective SIL.</p> <p>The total of both required SILs is not greater than the capability of the logic solver. (e.g. SIL1 pre-heat trip and a SIL2 furnace pressure trip = total SIL3 to prevent a fan low air flow from causing a combustibles explosion).</p> <p>It is recommended that during LOPA studies, the higher end of the selected SIL PFD range be applied as a placeholder, subject to a random hardware reliability analysis to determine the actual PFD. For example, if credit is taken for a SIL2-rated SIF as an IPL, a PFD of 0.01 should be taken until the actual PFD is determined.</p> |

5.3. SIL Verification Assumptions

The following points summarise the general assumptions used in the analysis. Where possible, specific paragraph references provide the context of the assumption, indicating where it has been applied.

1. If a failure occurs, it is assumed that on average it will occur at the mid-point of the test interval. In other words, the fault will remain undetected for 50% of the test period;
2. The analysis assumes constant failure rates and therefore the effects of early failures are expected to be removed by appropriate processes;
3. Components are not operated beyond their useful life thus ensuring that failures due to wear-out mechanisms do not occur;
4. It is assumed that the SIFs, as defined in Appendix A (Section 11), are sufficient to achieve a safe state;
5. It is assumed that the requirements stated in equipment safety manuals (if applicable) have been adhered to.
6. The proof test interval has been assumed to be once every 2 years;
7. The Proof Test Coverage (PTC) has been assumed to be 100%;
8. The Mean Time to Repair (MTTR) has been assumed to be 8 hours. Spares of key components and maintenance personnel are available onsite.
9. A β factor of 5% for redundant logic solver subsystems and 10% for redundant sensors final element subsystems have been assumed to account for Common Cause Failures (CCFs).
10. Failure rate data in Appendix D (Section 14) have been used for the SIL assessment.

6. METHODOLOGY

6.1. Methodology for SIL Determination

6.1.1. General Concept of Risk Reduction

The purpose of determining the tolerable risk for a specific hazardous event is to state what is deemed reasonable with respect to both the frequency of the hazardous event and its specific consequences.

The tolerable risk will depend on many factors, including the severity of the consequences or injury, the number of people exposed to danger, and the frequency and the duration of the exposure. Important factors will be the perception and views of those exposed to the hazardous event.

Risk reduction is achieved by a combination of all of the available safety protective features, including any associated SIF. The necessary risk reduction to achieve the specified tolerable risk, from a starting point of the risk presented by the Equipment Under Control (EUC), is shown in Figure 2.




Figure 2. The Concept of Risk Reduction

6.1.2. Risk and Safety Integrity Level

Safety integrity applies to the Electrical / Electronic / Programmable Electronic (E/E/PE) SIF, other technology safety instrumented systems and external risk reduction facilities and is a measure of the likelihood of those systems satisfactorily achieving the necessary risk reduction. Once the tolerable risk has been set, and the necessary risk reduction estimated, the safety integrity requirements for the SIFs can be allocated in terms of PFD or PFH. The PFD and PFH correspond to one of SILs specified in Table 3.

Table 3. SIL Specified PFD

| SIL | Low Demand (PFD) | High or Continuous Demand (PFH) |
|------|-------------------------------|---------------------------------|
| SIL4 | $\geq 10^{-5}$ to $< 10^{-4}$ | $\geq 10^{-9}$ to $< 10^{-8}$ |
| SIL3 | $\geq 10^{-4}$ to $< 10^{-3}$ | $\geq 10^{-8}$ to $< 10^{-7}$ |
| SIL2 | $\geq 10^{-3}$ to $< 10^{-2}$ | $\geq 10^{-7}$ to $< 10^{-6}$ |
| SIL1 | $\geq 10^{-2}$ to $< 10^{-1}$ | $\geq 10^{-6}$ to $< 10^{-5}$ |
| SILa | $\geq 10^{-1}$ to < 1 | N/A |

“SILa” indicates that although additional mitigation is required, the necessary level of risk reduction is below the SIL1 range and is thus outside the remit of IEC 61508 [2] and IEC 61511 [3]. If, however, an instrumented system is implemented to address a PFD target of greater than 0.1 (i.e. “SILa”), the UK Health and Safety Executive (HSE) requires said function to be subject to the following provisions [6]:

- the persons who have responsibilities for the instrumented system shall be suitably competent;
- clear, precise and unambiguous specification of the safety function;
- independence between control and safety functions wherever reasonably practicable;
- accurate, accessible, controlled and easily understood engineering documentation showing the component parts of the instrumented system and how they are configured. Examples of engineering documentation include loop or circuit diagrams, equipment data sheets and records of parameter settings;
- periodic inspection of the instrumented system, for example visual or more detailed inspection to reveal evidence of deterioration or unexpected modifications;
- periodic maintenance of the instrumented system, for example calibration, cleaning or flushing;
- periodic proof testing of the instrumented system for the purpose of revealing dangerous undetected faults;
- management of change, including control of access to software functions and backing up of software-based systems.

6.1.3. Risk Targets

In UK, HSE guidance on tolerable levels of risk (Reducing Risks, Protecting People [8]) defines the following risk boundaries:

- *“Individual risk of death of one in a million per annum [1.0E-06/yr] for both workers and the public corresponds to a very low level of risk and should be used as a guideline for the boundary between the broadly acceptable and tolerable regions”*
- *“Boundary between the ‘tolerable’ and ‘unacceptable’ regions for risk entailing fatalities [...] as individual risk of death of one in a thousand [1.0E-03/yr] per annum [...] for workers”.*

Given the inherent inaccuracies in the data applied in SIL determination studies, it was deemed prudent to set the tolerable risk as an order of magnitude lower than the ‘tolerable risk boundary’; i.e.1.0E-04/yr. For SIL targeting purposes, this value was typically reduced by a further order of magnitude to account for other, non-process risks of fatality (i.e. slips, trips and falls) to which the hypothetical employee may be exposed.

For the PSS0 SIL study, a more stringent target risk of 1.0E-06 per year was applied as the target for a single employee fatality, as per the PSS0 Hazard Register.

6.1.4. SIL Determination using LOPA

6.1.4.1. General

The assignment of SIL targets was achieved using the LOPA technique, as described in IEC 61511-3 [3] and the AIChE CCPS LOPA 2001 [5].

6.1.4.2. The LOPA Process for Low Demand SIFs

1. Identify hazards (which can be addressed by the implementation of a SIF) using a suitable Process Hazard Analysis tool (e.g. Hazard and Operability Study - HAZOP);
2. Rank the severity of the consequences of the specified hazard. **It is important that existing protection layers are disregarded at this stage.** Compare this with the corresponding risk target in Section 6.1.3;
3. Identify initiating events and estimate their frequency using operating experience where applicable, data sources such as FARADIP [10] and engineering judgement;
4. Identify Conditional Modifiers / Post-Event Mitigation. For example, occupancy, probability of ignition and vulnerability;
5. Identify Independent Protection Layers (IPLs), which prevent the hazardous event from occurring;
6. Determine the likelihood of occurrence (Total Mitigated Event Frequency);

This is calculated by applying equation (1):

$$f^c = \sum_{i=1}^K \left[f_i^I \times \left(\prod_{j=1}^M PFD_{ij}^{PL} \right) \times \left(\prod_{k=1}^N P_{ik}^{CM} \right) \right], \quad (1)$$

where:

f^c is the calculated frequency of consequence C summed over all relevant initiating events and with credit taken for all relevant protection layers and conditional modifiers/post-event mitigations: “Total Mitigated Event Frequency”

f_i^I is the frequency of initiating event i leading to consequence C.

PFD_{ij}^{PL} is the probability of failure on demand of the j^{th} protection layer that protects against consequence C for initiating event i . See “Independent Protection Layers”

P_{ik}^{CM} is the probability that conditional modifier k will allow consequence C to occur for initiating event i . See “Conditional Modifiers”

7. Compare the Target Risk Frequency with the likelihood of occurrence (Total Mitigated Event Frequency) to determine the required PFD for the SIF under consideration. This is calculated by applying equation (2).

$$PFD_{required} = \frac{f^T}{f^c}, \quad (2)$$

where:

f^T is the Target Risk Frequency

8. Determine the SIL requirement of the SIF under consideration by comparing the calculated PFD requirement with Table 3.

6.1.4.3. The LOPA Process for High or Continuous Demand SIFs

1. Identify hazards (which can be addressed by the implementation of a SIF) using a suitable Process Hazard Analysis tool (e.g. Hazard and Operability Study - HAZOP);
2. Rank the severity of the consequences of the specified hazard. **It is important that existing protection layers are disregarded at this stage.** Compare this with the corresponding risk target in Section 6.1.3;
3. Identify Conditional Modifiers / Post-Event Mitigation. For example, occupancy, probability of ignition and vulnerability;
4. Identify Independent Protection Layers (IPLs), which prevent the hazardous event from occurring;
5. Determine the Target Risk Frequency (/hr).
6. This is calculated by applying equation (3):

$$f^T = \left(\prod_{j=1}^M PFD_{ij}^{PL} \right) \times \left(\prod_{k=1}^N P_{ik}^{CM} \right), \quad (3)$$

where:

PFD_{ij}^{PL} is the probability of failure on demand of the j^{th} protection layer that protects against consequence C for initiating event i . See “Independent Protection Layers”

P_{ik}^{CM} is the probability that conditional modifier k will allow consequence C to occur for initiating event i .

f^T is the Target Risk Frequency

7. Determine the SIL requirement of the SIF under consideration by comparing the calculated PFH requirement with Table 3.

6.1.4.4. Independent Protection Layers (IPLs)

In order for an IPL to be considered valid (in accordance with IEC 61511-3 [3]), the following criteria must be met:

1. **Effectiveness** – an IPL reduces the identified risk by at least a factor of 10;

2. **Specificity** – an IPL is designed to prevent or mitigate the consequences of one potentially hazardous event. Multiple causes may lead to the same hazardous event, and therefore multiple event scenarios may initiate action by a PL;
3. **Independence** – an IPL is independent of other protection layers if it can be demonstrated that there is no potential for common cause or common mode failure with any other claimed IPL;
4. **Dependability** – an IPL can be counted on to do what it was designed to do by addressing both random failures and systematic failures during its design;
5. **Auditability** – a protection layer is designed to facilitate regular validation of the protective functions.

In order to help achieve and maintain the Auditability criteria (item 5 above), a database of all IPLs applied in this study is presented in Appendix B (Section 12). For the purposes of PFD estimation, it is assumed that all stated IPLs are tested at a proof test interval stated in Section 5.

6.1.5. SIL Determination Results

The LOPA worksheets are presented in Appendix C (Section 13), and the results, together with the established SIL assignment(s), are summarised in Section 13.

6.2. Hardware Reliability Assessment Methodology

6.2.1. Definition of Safety Integrity Level

The hardware reliability of a SIF is expressed in terms of either its Probability of Dangerous Failure on Demand (PFD) or of its Average Frequency of a Dangerous Failure per Hour (PFH¹), depending on the frequency of demands made upon it.

The frequency of demand ('mode of operation') on the SIF falls into three categories:

- low demand mode (IEC 61508-4: 3.5.16 [2]) – where the safety function is only performed on demand, in order to transfer the EUC into a specified safe state, and where the frequency of demands is no greater than one per year; or
- high demand mode (IEC 61508-4: 3.5.16 [2]) – where the safety function is only performed on demand, in order to transfer the EUC into a specified safe state, and where the frequency of demands is greater than one per year; or
- continuous mode (IEC 61508-4: 3.5.16 [2]) - where the safety function retains the EUC in a safe state as part of normal operation.

¹ The term "probability of dangerous failure per hour" is not used in IEC 61508 **Error! Reference source not found.** but the acronym PFH was retained. When it is used, it means "average frequency of a dangerous failure [h⁻¹]"

6.2.2. Probability of Failure on Demand

For low demand SIFs (refer to section 6.2.1), IEC 61508 [2] requires calculation of the PFD of each complete SIF loop:

$$PFD_{sys} = PFD_s + PFD_L + PFD_{FE} \quad (\text{IEC 61508-6: B.3.2.1 [2]}), \quad (4)$$

where:

PFD_{sys} is the probability of failure on demand of a safety function for the electrical/electronic/programmable electronic safety-related system;

PFD_s is the probability of failure on demand for the sensor subsystem;

PFD_L is the probability of failure on demand for the logic subsystem;

PFD_{FE} is the probability of failure on demand for the final element or final element subsystem.

The overall PFD of the complete SIF is compared with its PFD target to determine whether sufficient risk reduction is provided.

6.2.3. Failure Rate, λ

6.2.3.1. General

To calculate the PFD and PFH, it is first necessary to introduce the term 'failure rate'.

Failure rate is denoted by λ and defined as the *number of failures per unit time*.

6.2.3.2. Failure Modes

In order to calculate the PFD of the sensor, logic or final element subsystem using λ , its failure modes must first be examined. The number of failures is apportioned into safe and dangerous failure modes, where:

- A **dangerous failure** (IEC 61508-4: 3.6.7 [2]) is defined as a failure of an element and/or subsystem and/or system that plays a part in implementing the safety function that:
 - prevents a safety function from operating when required (demand mode) or causes a safety function to fail (continuous mode) such that the EUC is put into a hazardous or potentially hazardous state; or
 - decreases the probability that the safety function operates correctly when required
- A **safe failure** (IEC 61508-4: 3.6.8 [2]) is defined as a failure of an element and/or subsystem and/or system that plays a part in implementing the safety function that:

- results in the spurious operation of the safety function to put the EUC (or part thereof) into a safe state or maintain a safe state; or
- increases the probability of the spurious operation of the safety function to put the EUC (or part thereof) into a safe state or maintain a safe state

It follows that the total failure rate, λ , is equal to the sum of the safe and dangerous failure rates:

$$\lambda = \lambda_D + \lambda_S, \quad (5)$$

where:

λ_D is the dangerous failure rate per hour and;

λ_S is the safe (or spurious) failure rate per hour.

6.2.3.3. Diagnostic Testing

The dangerous failure rate is further apportioned into dangerous detected and undetected failures, where:

- A **detected** failure (overt) [IEC 61508-4: 3.8 [2]] is defined as a failure, in relation to hardware, detected by the diagnostic tests, proof tests, operator intervention (for example physical inspection and manual tests), or through normal operation
- An **undetected** failure (covert) [IEC 61508-4: 3.8.9 [2]] is defined as a failure, in relation to hardware, undetected by the diagnostic tests, proof tests, operator intervention (for example physical inspection and manual tests), or through normal operation

The relationship can therefore be described by:

$$\lambda_D = \lambda_{DD} + \lambda_{DU}, \quad (6)$$

where:

λ_{DD} is the dangerous detected failure rate per hour and;

λ_{DU} is the dangerous undetected failure rate per hour.

6.2.4. PFD and Mean Down Time (MDT)

6.2.4.1. General

The PFD of a single subsystem - for instance, a single detector - is found by multiplying the dangerous failure rate, λ_D (refer to Section 6.2.3.2), by the Mean Down Time (MDT):

$$PFD = \lambda_D MDT, \quad (7)$$

where MDT is the time taken to repair a fault and is, itself, defined as the Mean Time To Repair (MTTR), plus the time taken to detect it. It is assumed that, on average, a fault will occur at the mid-point of the test interval and, thus, the time taken to detect a fault is equal to half the test interval, $T/2$. Therefore:

$$MDT = MTTR + T/2, \quad (8)$$

6.2.4.2. PFD for Detected Failures

In general, for failures that are detected by the diagnostic tests of a subsystem (refer to Section 6.2.3.3), the test interval (termed as 'diagnostic test interval'), T_d , is typically less than one (1) hour (refer to IEC 61508-6: Annex B [2]) and, thus, the time taken to detect a fault, $T_d/2$, is considered small in comparison with the MTTR. That is:

$$MDT_{(Detected)} \approx MTTR, \text{ and thus:}$$

$$PFD_{(Detected)} = \lambda_{DD} MTTR, \quad (9)$$

where MTTR is measured in hours.

6.2.4.3. PFD for Undetected Failures

For undetected failures (refer to Section 6.2.3.3), i.e. failures revealed only by manual proof testing, the MTTR is considered small in comparison with the time taken to detect a fault, i.e. the mid-point of the proof test interval, $T_p/2$; therefore:

$$MDT_{(Undetected)} \approx T_p / 2,$$

and thus:

$$PFD_{(Undetected)} = \lambda_{DU} T_p / 2, \quad (10)$$

where T_p is the proof test interval in hours.

6.2.4.4. PFD for Subsystem

The overall PFD of a single subsystem (sensor, logic or final element subsystem), comprises the PFD for undetected faults and the PFD for detected faults:

$$PFD_{\text{subsystem}} = PFD_{(Undetected)} + PFD_{(Detected)}. \quad (11)$$

6.2.4.5. PFH for Subsystem

The PFH of a single subsystem - for instance, a single detector - is equivalent to its dangerous undetected failure rate, λ_{DU} (refer to Section 6.2.3.3).

$$PFH_{\text{subsystem}} = \lambda_{DU} \quad (12)$$

6.2.5. Voting Configurations

When a subsystem (sensor, logic or final element) consists of several components, such as sensors in a two out of three (2oo3) voting configuration, the combined PFD of the whole subsystem must be calculated. The PFD for subsystems in different configurations are found using the formulae presented in IEC 61508 [2].

The reliability analysis for subsystems in redundant configurations was conducted using the FTA.

6.2.6. Common Cause Failure (CCF)

When assessing the reliability of a subsystem in a redundant configuration, IEC 61508 [2] requires that the effect of CCFs is taken into account. A CCF is defined as: *a failure that is the result of one or more events, causing failures of two or more separate channels in a multiple channel system.*

An example of a CCF would be freezing weather conditions causing identical level transmitters in a 1oo2 voting configuration to fail simultaneously.

CCFs in redundant systems are accounted for using the β model, which assumes a fixed proportion of failures are caused by a common cause. This proportion, termed β , is estimated based on:

- the degree of channel separation;
- design with common cause awareness;
- diagnostic coverage;
- self-test frequency and other factors.

The CCF rate, according to the β model, is calculated as follows:

$$\lambda_{Common Cause} = \beta\lambda_{DD} + \beta\lambda_{DU} \quad (13)$$

and, thus, the overall PFD due to dangerous CCFs is given by:

$$PFD_{(Common Cause)} = \beta\lambda_{DD}MTTR + \beta\lambda_{DU}T_p / 2 \quad (14)$$

6.3. Architectural Assessment Methodology

6.3.1. Hardware Fault Tolerance (HFT)

In addition to the hardware reliability assessment (refer to Section 6.2), there are also minimum architecture requirements to be met. Each subsystem within a SIF must meet the minimum HFT for the required SIL. That is, the sensor, logic and final element subsystems must all individually meet the overall SIL requirement for the SIF. To determine the level of HFT (or redundancy) required in a SIF using the Route 1_H approach detailed in IEC 61508-2: 7.4.4.2, the Safe Failure Fraction (SFF) must be calculated for each subsystem.

6.3.2. Safe Failure Fraction (SFF)

The SFF is essentially the proportion of random failures in a subsystem that either result in a safe state, or a dangerous state that is revealed by automatic diagnostic tests. SFF is calculated using the following formula:

$$SFF = \frac{\lambda_{DD} + \lambda_s}{\lambda_{DD} + \lambda_{DU} + \lambda_s} \quad (\text{IEC 61508-2: C.1.h [2]}), \quad (15)$$

where:

λ_{DD} is the dangerous detected failure rate per hour;

λ_{DU} is the dangerous undetected failure rate per hour;

λ_s is the safe (spurious) failure rate per hour.

6.3.3. IEC 61508 Architectural Constraints (Route 1_H)

Table 4 presents the (Route 1_H) minimum HFT for Type A and Type B components respectively. For a component to be considered Type A, all the following criteria must be met:

- Failure modes are well defined and;
- Behaviour under fault conditions is well defined and;
- Failure data is available.

If a component fails to meet any of these criteria, it is considered to be Type B. Type B components typically contain complex microelectronics, commonly found in Programmable Logic Controllers (PLCs) and smart sensors. Simple devices, such as valves and relays, are typically considered to be Type A.

Table 4. HFT for Type A and Type B Components

| SFF | Minimum HFT for Type A Component | | | Minimum HFT for Type B Component | | |
|--------|----------------------------------|-------------|-------------|----------------------------------|-------------|-------------|
| | SIL for simplex | SIL for m+1 | SIL for m+2 | SIL for simplex | SIL for m+1 | SIL for m+2 |
| | (HFT=0) | (HFT=1) | (HFT=2) | (HFT=0) | (HFT=1) | (HFT=2) |
| <60% | 1 | 2 | 3 | Not allowed | 1 | 2 |
| 60-90% | 2 | 3 | 4 | 1 | 2 | 3 |
| 90-99% | 3 | 4 | 4 | 2 | 3 | 4 |
| >99% | 4 | 4 | 4 | 3 | 4 | 4 |

7. RESULTS

The results of the SIL Assessment are summarised in Table 5 and Table 6.

Table 5. Summary of Results – LOW Demand SIFs

| SIF Tag | SIF Description | Hazardous Event (Deviation) | Selected PFD Target | PFD Achieved | Selected SIL Target | Max Allowable SIL (Architectural Constraints) | Result | Status |
|---|---|--|---------------------|--------------|---------------------|---|--------|--------|
| SIF02 – HV interlock upon intrusion to PSS0 controlled area | Upon detecting access gate in open position (1oo2 position switch), shutdown HV by removing its power supply (1oo2 relay and contactor) via Safety PLC (1oo2, blue and red trains). | High / More Power leading to (Safety) Electric shock | 1.0E-3 | 7.7E-4 | SIL 2 | SIL 3 | Passed | Closed |

Table 6. Summary of Results – HIGH Demand SIFs

| SIF Tag | SIF Description | Hazardous Event (Deviation) | Selected PFH Target | PFH Achieved | Selected SIL Target | Max Allowable SIL (Architectural Constraints) | Result | Status |
|--|---|--|---------------------|--------------|---------------------|---|--------|--------|
| SIF03 – HV interlock – PSS0 key exchange | Upon detecting access key is removed (key switch in off position), shutdown HV by removing its power supply (1oo2 relay and contactor) via Safety PLC (1oo2, blue and red trains). Additionally, it also closes an earth relay to remove any residual stored energy from the power supply and its output cable. | High / More Power leading to (Safety) Electric shock | 1.1E-7 | 1.1E-7 | SIL 2 | SIL 2 | Passed | Closed |
| SIF04 – Door lock – PSS0 key exchange | Upon detecting access key is removed from Slot 2, lock the Access Gate (de-energising 1oo1 solenoid) via Safety PLC (1oo2, blue and red trains). | High / More Power leading to (Safety) Electric shock | 1.1E-7 | 6.0E-8 | SIL 2 | SIL 2 | Passed | Closed |

8. CONCLUSIONS AND RECOMMENDATIONS

All assessed SIFs meet their required SIL determined by the LOPA, in terms of achieved PFD or PFH and the architectural constraints assessment.

For the emergency exit to be an effective layer of protection, it is recommended to implement a HV ON warning within the PSS0 controlled area.

9. GLOSSARY

| Term | Definition |
|----------------|---|
| /hr | per hour |
| /yr | per year |
| β | Common cause beta factor, presented as percentage |
| λ | Failure Rate |
| λ_{DU} | Dangerous Undetected Failure Rate |
| λ_{DD} | Dangerous Detected Failure Rate |
| λ_D | Dangerous Failure Rate |
| λ_S | Safe Failure Rate |
| AIChE | American Institute of Chemical Engineers |
| BPCS | Basic Process Control System |
| CCF | Common Cause Failure |
| CCPS | Center for Chemical Process Safety |
| E/E/PE | Electrical / Electronic / Programmable Electronic |
| ERIC | European Research Infrastructure Consortium |
| ESC | Engineering Safety Consultants |
| ESS | European Spallation Source |
| ETA | Event Tree Analysis |
| EUC | Equipment Under Control |
| FAT | Factory Acceptance Test |
| FSA | Functional Safety Assessment |
| FTA | Fault Tree Analysis |
| HAZAN | Hazard Analysis |
| HAZID | Hazard Identification |

| Term | Definition |
|----------------|---|
| HAZOP | Hazard and Operability |
| HFT | Hardware Fault Tolerance |
| HSE | Health and Safety Executive |
| HV | High Voltage |
| ICS | Integrated Control System |
| ID | Identifier |
| IE | Initiating Event |
| IEC | International Electrotechnical Commission |
| IPL | Independent Protection Layer |
| LOPA | Layers of Protection Analysis |
| MDT | Mean Down Time |
| MRT | Mean Repair Time |
| MTTR | Mean Time To Repair |
| oo | out of (voting configuration) |
| O&M | Operation and Maintenance |
| PLC | Programmable Logic Controller |
| PFH | Probability of Failure per Hour |
| PFD | Probability of Failure on Demand |
| PSS | Personnel Safety System |
| PTC | Proof Test Coverage |
| RBD | Reliability Block Diagram |
| SFF | Safe Failure Fraction |
| SIF | Safety Instrumented Function |
| SIL | Safety Integrity Level |
| SIS | Safety Instrumented System |
| T _p | Proof Test Interval |

10. REFERENCES

- [1] ESS-0229506: PSS0 Hazard and Risk Analysis Document.
- [2] IEC 61508:2010, Functional safety of electrical/ electronic/ programmable electronic safety related systems.
- [3] IEC 61511: 2016, Functional safety – Safety instrumented systems for the process industry sector.

- [4] ESS-0229491: PSSO Hazard Register.
- [5] The American Institute of Chemical Engineers (AIChE) Center for Chemical Process Safety (CCPS) Layer of Protection Analysis (LOPA) 2001.
- [6] UK HSE document: Management of instrumented systems providing safety functions of low / undefined safety integrity (http://www.hse.gov.uk/foi/internalops/hid_circs/technical_general/spc-tech-gen-51.htm#action). Accessed 10th June 2014.
- [7] ESC SIL Determination Rule Set: Document Ref. P001_ID090.
- [8] HSE document: Reducing risks, protecting people (R2P2), 2001, ISBN 0-7176-2151-0.
- [9] Reliability, Maintainability and Risk, DJ Smith, 8th Edition, Butterworth-Heinemann, ISBN 9780080969022.
- [10] FARADIP - THREE V9.2, Reliability Data Base, Technis, 26 Orchard Drive, Tonbridge, Kent, TN10 4LG, ISBN 0-951-65623-6.
- [11] PSSO safety device failure rate data file, MS Excel file "RBD data Standards added.xlsx".

Review

11. APPENDIX A – SIF DEFINITIONS

| SIF Tag | SIF Description | Sensor Subsystem | Sensor Subsystem Configuration | Logic Subsystem | Logic Subsystem Configuration | Final Element Subsystem | Final Element Subsystem Configuration |
|---|---|------------------|--------------------------------|-----------------|-------------------------------|--------------------------------|---------------------------------------|
| SIF01 – HV Emergency Stop | Upon detecting the emergency stop button being pressed, shutdown HV by removing its power supply (1oo2 relay and contactor) via Safety PLC (1oo2, blue and red trains). | PB001 | 1oo1 | LS001, LS002 | 1oo2 | Relay001, C001, Relay002, C002 | 1oo2 |
| SIF02 – HV interlock upon intrusion to PSS0 controlled area | Upon detecting access gate in open position (1oo2 position switch), shutdown HV by removing its power supply (1oo2 relay and contactor) via Safety PLC (1oo2, blue and red trains). | sw_mag, sw_mech | 1oo2 | LS001, LS002 | 1oo2 | Relay001, C001, Relay002, C002 | 1oo2 |

| SIF Tag | SIF Description | Sensor Subsystem | Sensor Subsystem Configuration | Logic Subsystem | Logic Subsystem Configuration | Final Element Subsystem | Final Element Subsystem Configuration |
|--|---|------------------|--------------------------------|-----------------|-------------------------------|--------------------------------|---------------------------------------|
| SIF03 – HV interlock – PSS0 key exchange | Upon detecting access key is removed (key switch in off position), shutdown HV by removing its power supply (1oo2 relay and contactor) via Safety PLC (1oo2, blue and red trains). Additionally, it also closes an earth relay to remove any residual stored energy from the power supply and its output cable. | sw_key | 1oo1 | LS001, LS002 | 1oo2 | Relay001, C001, Relay001, C001 | 1oo2 |
| SIF04 – Door lock – PSS0 key exchange | Upon detecting access key is removed from Slot 2, lock the Access Gate (de-energising 1oo1 solenoid) via Safety PLC (1oo2, blue and red trains). | sw_key | 1oo1 | LS001, LS002 | 1oo2 | Solenoid | 1oo1 |
| SIF05 – HV ON warning light | HV ON warning light activated when Access Key at Slot 1 in On position. | sw_key | 1oo1 | LS001, LS002 | 1oo2 | Mains, UPS | 1oo2 |
| | | | | | | WarnLight | 1oo1 |

Document Type Analysis Report
Document Number ESS-0231390
Revision 1 (1)

Date Feb 6, 2018
State Review
Confidentiality Level Internal

Notes:

- SIF01 was designed to prevent equipment damage in cases of fire or explosion. It is not used for personnel protection and not taken as safeguard for the electric shock hazard. Therefore it has been excluded from any further assessment.
- SIF05 is not a SIF by definition, as it does not put the system in a safe state. However, this function is provided by PSS0. It will be treated as part of administrative control and excluded from any further assessment.

Review

12. APPENDIX B – IPL REGISTER

| Tag | Type | Description | Justification |
|---|---------------|---|--|
| SIF05 – HV ON warning light | Alarms | HV on warning light and sign | Administrative control |
| SIF02 – HV interlock upon intrusion to PSS0 controlled area | SIF | Upon detecting access gate opening, isolate power sources to HV via Safety PLC | Placeholder PFD of 1.0E-02 used, pending SIL verification |
| Formalised Search | Human Factors | Formalised search by personnel. HV is inhibited prior to successful completion of the formalised search. | Personnel conducting the search in a small area, with the aid of the safety system |
| Emergency Exit | Human Factors | Emergency exit door available, can be opened from inside. Upon door opening, HV will be shutdown (part of AccessGate SIF) | This requires personnel to take action by pushing the emergency exit door |
| Grounding Rod | Human Factors | Procedure requires personnel to put the grounding rod in place upon entering PSS0 controlled area. | Trained personnel following written procedure |

| Tag | Type | Description | Justification |
|--|---------------|---|---|
| SIF03 – HV interlock – PSS0 key exchange | SIF | Key exchange system: Upon detecting access key is removed (key switch in off position), shutdown HV by removing its power supply (1002 relay and contactor) via Safety PLC (1002, blue and red trains). Additionally, it also closes an earth relay to remove any residual stored energy from the power supply and its output cable. | A placeholder PFD of 1.0E-02 used, pending SIL verification |
| SIF04 – Door lock – PSS0 key exchange | SIF | SIF - Key exchange system: Upon detecting access key is removed from Slot 2, lock the Access Gate (de-energising 1001 solenoid) via Safety PLC (1002, blue and red trains). | A placeholder PFD of 1.0E-02 used, pending SIL verification |
| Procedures | Human Factors | Procedures for formalised search, and grounding rod placement | Trained personnel following written procedure |

13. APPENDIX C – SIL ASSESSMENT WORKSHEETS

SIF02 – HV interlock upon intrusion to PSS0 controlled area

This SIF applies to HZ003 IE01 – Personnel attempts access to PSS0 controlled area (when HV is ON).


LOPA Worksheets

| | | | | | | | |
|-----------------------------|---|--|----------------|---|---------------------------------------|-------------------|-------------------|
| HAZARD ID | HAZ003 IE01 | | SIF Tag | SIF02 – HV interlock upon intrusion to PSS0 controlled area | | | |
| Drawing Numbers | | | | | | | |
| SIF Description | Upon detecting access gate in open position (1oo2 position switch), shutdown HV by removing its power supply (1oo2 relay and contactor) via Safety PLC (1oo2, blue and red trains). | | | | | | |
| Hazardous Event (Deviation) | High / More Power leading to (Safety) Electric shock | | | | | | |
| Mode Of Operation | Low Demand | Nodes | 1 | | | | |
| Notes | | | | | | | |
| LOPA Summary | | | | | | | |
| Category | Target Risk Frequency (/yr) | Consequence Description | | | Total Inter. Event Freq. (/yr) | PFD Target | SIL Target |
| Safety | 1.0E-6 | Fatality / Serious Disability / Life Threatening Health Effect | | | 1.0E-3 | 1.0E-3 | SIL 2 |
| Selected SIL Target | | | | | | | SIL 2 |

| Ref. | Initiating Events | | IPLs | | No Modifiers | Inter. Event Freq. (/yr) |
|------|--|-------------|------|---|--------------|--------------------------|
| | Description / Justification | Freq. (/yr) | A | B | Type | |
| 1 | Personnel attempt to access PSS0 controlled area, whilst HV is On. | 1.0E0 | Y | Y | Safety | 1.0E-3 |
| | Estimated to be 1 per year. | | | | | |


| IPLs / Conditional Modifiers | | | | |
|------------------------------|--------|---------------------------------------|--|--------|
| Ref. | Type | Tag | Description / Justification | Credit |
| A | Alarms | SIF05 – HV ON warning light | HV on warning light and sign | 1.0E-1 |
| | | | Administrative control | |
| B | SIF | SIF04 – Door lock – PSS0 key exchange | Upon detecting access key is removed from Slot 2, lock the Access Gate (de-energising 1oo1 solenoid) via Safety PLC (1oo2, blue and red trains). | 1.0E-2 |
| | | | A placeholder PFD of 1.0E-02 used, pending SIL verification | |

RBD (Reliability Block Diagram)



FTA

The FTA shows the achieved PFD for SIF02 is 7.7E-04. This falls into SIL 3 band.



SIF03 – HV interlock – PSS0 key exchange

This SIF applies to HZ003 IE02 – HV is turned on by mistake (human error).


LOPA Worksheets

| HAZARD ID | HAZ003 IE02 | | SIF Tag | SIF03 – HV interlock – PSS0 key exchange | | | |
|-----------------------------|---|--|-------------------|--|------------|--------------|--|
| Drawing Numbers | | | | | | | |
| SIF Description | Upon detecting access key is removed (key switch in off position), shutdown HV by removing its power supply (1oo2 relay and contactor) via Safety PLC (1oo2, blue and red trains). Additionally, it also closes an earth relay to remove any residual stored energy from the power supply and its output cable. | | | | | | |
| Hazardous Event (Deviation) | High / More Power leading to (Safety) Electric shock | | | | | | |
| Mode Of Operation | Continuous | Nodes | 1 | | | | |
| Notes | | | | | | | |
| LOPA Summary | | | | | | | |
| Category | Target Risk Frequency (/hr) | Consequence Description | Total IPL Factors | Total Modifier Factors | PFH Target | SIL Target | |
| Safety | 1.1E-10 | Fatality / Serious Disability / Life Threatening Health Effect | 1.0E-3 | | 1.1E-7 | SIL 2 | |
| Selected SIL Target | | | | | | SIL 2 | |

| Ref. | Initiating Events | | IPLs | | No Modifiers | |
|------|---|-------|------|---|--------------|--|
| | Description / Justification | Freq. | A | B | Type | |
| 1 | Failure of SIF | N/A | Y | Y | Safety | |
| | SIF defined as High Demand (>1 demand per year) | | | | | |


| IPLs / Conditional Modifiers | | | | |
|------------------------------|---------------|----------------|--|--------|
| Ref. | Type | Tag | Description / Justification | Credit |
| A | Human Factors | Procedures | Procedures for formalised search, and grounding rod placement | 1.0E-2 |
| | | | Trained personnel following written procedure | |
| B | Human Factors | Emergency Exit | Emergency exit door available, can be opened from inside. Upon door opening, HV will be shutdown (part of SIF for HV interlock upon intrusion to PSS0 controlled area) | 1.0E-1 |
| | | | This requires personnel to take action by pushing the emergency exit door | |

RBD



FTA

The FTA shows the achieved PFH for SIF03 is 9.7E-04 per year, which is 1.1E-07 per hour. This falls into SIL 2 band.



SIF04 – Door lock – PSS0 key exchange

This SIF applies to HZ003 IE01 – Personnel attempts access to PSS0 controlled area (when HV is ON).


LOPA Worksheets

| HAZARD ID | HAZ003 IE01 | | SIF Tag | SIF04 – Door lock – PSS0 key exchange | | | |
|-----------------------------|--|--|-------------------|---------------------------------------|------------|--------------|--|
| Drawing Numbers | | | | | | | |
| SIF Description | Upon detecting access key is removed from Slot 2, lock the Access Gate (de-energising 1001 solenoid) via Safety PLC (1002, blue and red trains). | | | | | | |
| Hazardous Event (Deviation) | High / More Power leading to (Safety) Electric shock | | | | | | |
| Mode Of Operation | Continuous | Nodes | 1 | | | | |
| Notes | | | | | | | |
| LOPA Summary | | | | | | | |
| Category | Target Risk Frequency (/hr) | Consequence Description | Total IPL Factors | Total Modifier Factors | PFH Target | SIL Target | |
| Safety | 1.1E-10 | Fatality / Serious Disability / Life Threatening Health Effect | 1.0E-3 | | 1.1E-7 | SIL 2 | |
| Selected SIL Target | | | | | | SIL 2 | |

| Ref. | Initiating Events | IPLs | | No Modifiers | |
|------|---|-------|---|--------------|--------|
| | Description / Justification | Freq. | A | B | Type |
| 1 | Failure of SIF | N/A | Y | Y | Safety |
| | SIF defined as High Demand (>1 demand per year) | | | | |


| IPLs / Conditional Modifiers | | | | |
|------------------------------|--------|---|--|--------|
| Ref. | Type | Tag | Description / Justification | Credit |
| A | Alarms | WarnSign | HV on warning light and sign | 1.0E-1 |
| | | | Administrative control | |
| B | SIF | SIF02 – HV interlock upon intrusion to PSS0 controlled area | Upon detecting access gate opening, isolate power sources to HV via Safety PLC | 1.0E-2 |
| | | | Placeholder PFD of 1.0E-02 used, pending SIL verification | |

RBD



FTA

The FTA shows the achieved PFH for SIF04 is 5.3E-04 per year, which is 6.0E-08 per hour. This falls into SIL 3 band.



14. APPENDIX D – FAILURE RATE DATA

| Device Tag | Manufacturer | Device | Proof Testing Interval (Months) | Proof Testing Coverage (%) | MRT (Hours) | Dangerous Failure Mode | λ_{DD} (/hr) | λ_{DU} (/hr) | λ_S (/hr) | SFF (%) | Data Source | Type |
|--------------------|--------------|--|---------------------------------|----------------------------|-------------|-------------------------|----------------------|----------------------|-------------------|---------|--|------|
| C001, C002 | Siemens | SIRIUS Contactor 3RT1015-1BB41 [NOTE 1] | 24 | 100 | 8 | Fail to open | 0 | 4.0E-7 | 6.0E-7 | 60 | Siemens IC 10 catalog "Industrial Controls" issue 2015 chapter 16 pages 16-17, October 2015. | A |
| LS001, LS002 | Siemens | SIMATIC S7-1500F + Digital Input (F-DI 8x24VDC HF) + Digital Output (F-DQ 4xDC 24V/2A) | 24 | 100 | 8 | Fail to initiate action | 0 | 3.0E-9 | 3.0E-7 | 99 | Siemens device manual, December 2014 | B |
| Relay001, Relay002 | Siemens | SIRIUS Contactor 3RT1015-1BB41 [NOTE 1] | 24 | 100 | 8 | Fail to open | 0 | 4.0E-7 | 6.0E-7 | 60 | Siemens IC 10 catalog "Industrial Controls" issue 2015 chapter 16 pages 16-17, October 2015. | A |

| Device Tag | Manufacturer | Device | Proof Testing Interval (Months) | Proof Testing Coverage (%) | MRT (Hours) | Dangerous Failure Mode | λ_{DD} (/hr) | λ_{DU} (/hr) | λ_S (/hr) | SFF (%) | Data Source | Type |
|------------|---------------------|--|---------------------------------|----------------------------|-------------|-------------------------|----------------------|----------------------|-------------------|---------|--|------|
| Solenoid | Siemens | Solenoid door lock, de-energise to lock; Faradip data 0.4fpmh, 10% fail to release, 10% leak, 80% not energise | 24 | 100 | 8 | Failure to release | 0 | 4.0E-8 | 3.6E-7 | 90 | FARADIP-THREE v9.2 | A |
| sw_key | Fortress Interlocks | mGard S and SE key switch | 24 | 100 | 8 | Fail in open position | 0 | 2.0E-8 | 3.0E-8 | 60 | Manufacturers mGard Datasheet: SE key switch February 2015; S key switch October 2015 | A |
| sw_mag | Siemens | 3SE6604-2BA, SIGUARD Magnetically operated switching element | 24 | 100 | 8 | Fail in closed position | 0 | 5.0E-9 | 5.0E-9 | 50 | Overview of Safety-Related Parameters from Siemens Components in Accordance with ISO 13849-1 and IEC 62061, May 2013 | A |

| Device Tag | Manufacturer | Device | Proof Testing Interval (Months) | Proof Testing Coverage (%) | MRT (Hours) | Dangerous Failure Mode | λ_{DD} (/hr) | λ_{DU} (/hr) | λ_S (/hr) | SFF (%) | Data Source | Type |
|------------|--------------|---|---------------------------------|----------------------------|-------------|------------------------|----------------------|----------------------|-------------------|---------|---|------|
| sw_mech | Siemens | 3SE5312-0SH11, safety position switch with solenoid interlocking [NOTE 1] | 24 | 100 | 8 | Fail in open position | 0 | 2.0E-7 | 8.0E-7 | 80 | Siemens IC 10 catalog "Industrial Controls" issue 2015 Chapter 16 pages 16-17, October 2015 | A |

Note 1: Devices of the same type but with different part number from those listed in [11] are treated as standard device, i.e. not specifically designed for safety application, and non-safety related devices have been assigned a failure rate one order of magnitude higher than the corresponding safety-related devices in [11].

15. APPENDIX E – ETA

HAZ003 IE01

| Personnel attempt access to PSS0 controlled area, HV On | Warning light/sign | Key exchange system - Door locked when Access key removed from slot 2 | Access gate monitoring - HV Off on gate opening | Consequence | Frequency |
|---|--------------------|---|---|------------------------|-----------|
| w=1 | Q=0.1 | Q=0.0005269 | Q=0.0007726 | | 1 |
| | Success | Null | Null | No safety consequences | 0.9 |
| | | Success | Null | No safety consequences | 0.09995 |
| Failure:PSS0_HAZ003_IE01 | | | Success | No safety consequences | 5.265E-05 |
| | Failure | | Failure | Electric shock, <100kV | 4.071E-08 |

HAZ003 IE02

| HV expected to be turned on/off once each working day (248 working days per year). Operator is estimated to make a mistake (turning on HV when should not) 1 in 100 operations. | Occupancy factor: person in PSS0 controlled area when HV is off for about 50% of the time | Formalised search | SIF03 Key exchange with mechanically trapped keys (cannot access area without key, cannot turn on HV without key) | Supervisor provide clear instruction for operator in control room to turn on HV upon satisfying him self outside PSS0 controlled area. | Emergency exit door | Consequence | Frequency |
|---|---|-------------------|---|--|---------------------|------------------------|-----------|
| w=2.48 | Q=0.5 | Q=0.01 | Q=0.0009433 | Q=0.1 | Q=0.1 | | 2.48 |
| | Success | Null | Null | Null | Null | No safety consequences | 1.24 |
| | | Success | Null | Null | Null | No safety consequences | 1.228 |
| | | | Success | Null | Null | No safety consequences | 0.01239 |
| Failure:PSS0_HAZ003_IE02 | | | | Success | Null | No safety consequences | 1.053E-05 |
| | Failure | | | | Success | No safety consequences | 1.053E-06 |
| | | Failure | | Failure | | Electric shock, <100kV | 1.17E-07 |

HAZ003 IE03

| A person affected by residual voltage upon entering the PSS0 controlled area. | Key exchange system - HV Off on removing access key + earth relay | Warning light/sign (HV ON) and Entry Procedure (incl. wait until HV ON light off) | Ground rod placement procedure | Consequence | Frequency |
|---|---|---|--------------------------------|------------------------|-----------|
| w=52 | Q=0.0009433 | Q=0.1 | Q=0.1 | | 52 |
| Success | | | | No safety consequences | 51.95 |
| Null | | | | No safety consequences | 0.04415 |
| Success | | | | No safety consequences | 0.004415 |
| Failure:PSS0_HAZ003_IE03 | | | | No safety consequences | 0.0004905 |
| Failure | | | | No safety consequences | 0.0004905 |
| Failure | | | | No safety consequences | 0.0004905 |

Document Type Analysis Report
Document Number ESS-0231390
Revision 1 (1)

Date Feb 6, 2018
State Review
Confidentiality Level Internal

Note: upon HV shutdown, the capacitors and cable will discharge any residual energy in 250ms through the 10 MOhm resistors. Gaining access to the PSS0 controlled area using the key exchange system following HV shutdown would take longer than 250ms. As a result, the initiating event is not considered credible for any safety consequences.

Review

DOCUMENT REVISION HISTORY

| Revision | Reason for and description of change | Author | Date |
|----------|--------------------------------------|--------|------------|
| 1 | First issue | Fan Ye | 2018-02-05 |

Review